



Fair  
Trading

File Ref: CS10890N  
Contact: Admin Clerk  
Telephone: 02 9895 0722

Mr Wayne Callen  
World Wide Electrical Safety Technology Pty Ltd  
PO Box 268  
THE JUNCTION NSW 2291

Dear Sir/Madam

CERTIFICATE OF SUITABILITY: CS10890N

Voltage Monitor

Please find enclosed a Certificate of Suitability as sought by your application.

Articles of the approved type may be marked with the mark (or alternate approval mark) shown on the Certificate.

THE APPROVAL EXPIRES ON THE DATE SHOWN ON THE CERTIFICATE unless it is renewed, extended, suspended or cancelled.

Any sample/s held by this Office should be collected within fifteen (15) days of this letter or the sample/s will be destroyed.

Yours faithfully

  
For Commissioner for Fair Trading



**Fair  
Trading**

# Certificate of Suitability Non-Declared Article

**Certificate Number: CS10890N**

This is to certify that the article specified below is accepted by NSW FAIR TRADING as suitable for connection to public electricity supply in NEW SOUTH WALES in accordance with the provisions of AS/NZS 3000 and subject to the conditions stated.

<b>Issued to:</b>	World Wide Electrical Safety Technology Pty Ltd		
<b>Article:</b>	Voltage Monitoring Device (A neutral to earth voltage monitoring module with a functional earth monitoring wire and which triggers a paired approved residual current device to isolate the power when the neutral to earth voltage exceeds 43Vac +/- 5%.)		
<b>Trade Name or Mark:</b>	'RVT'		
<b>Ratings:</b>	<b>Volts:</b> 110/220 <b>Watts:</b>	<b>Amperes:</b> 10mA-30mA <b>Hertz:</b> 50/60 Hz	<b>Other Name Plate Particulars:</b> Class II
<b>Type Reference Code:</b>	VM-220-10		
<b>Examined for Compliance With:</b>	AS/NZS 3100: 2017 A1		
<b>Nominated Marking:</b>	CS10890N or approved alternate mark.		
<b>Date of Approval:</b>	08/07/2019		
<b>Approval Expires:</b>	08/07/2024 unless suspended, cancelled, renewed or extended.		

**Conditions:**

1. This certification will be withdrawn automatically if an article of this type is declared pursuant to the Electricity (Consumer Safety) Act, 2004.
2. This certificate is issued subject to the article and approved variations being maintained at the standard of the article examined at the time of approval.



On behalf of the Commissioner for Fair Trading

For current information regarding currency of certificate, refer to the Fair Trading Website